



## CITY OF ADELANTO SOLAR PV SYSTEM SUBMITTAL REQUIREMENTS

This information bulletin is published to guide applicants through a streamlined permitting process for solar photovoltaic (PV) projects 10 kW in size or smaller. This bulletin provides information about submittal requirements for plan review, required fees and inspections

### 1. Approval Requirements

An electrical permit is required to install a solar PV system with a maximum power output of 10 kW or less. Planning Division and Fire Department reviews are required and are included as part of the review.

### 2. Submittal Requirements

- a) Completed permit application form.
- b) Demonstrate compliance with the eligibility checklist for expedited permitting.
- c) A completed Standard Electrical Plan. The standard plan must be used for proposed solar installations 10 kW in size or smaller.
- d) A roof plan showing roof layout, PV panels and the following fire safety items: approximate location of roof access point, location of code-compliant access pathways, PV system fire classification and the locations of all required labels and markings. Examples of clear path access pathways are available in the State Fire Marshal Solar PV Installation Guide.  
<http://osfm.fire.ca.gov/pdf/reports/solarphotovoltaicguideline.pdf>.
- e) Completed expedited Structural Criteria along with required documentation.

### 3. Plan Review

Permit applications can be submitted to the City of Adelanto in person at 11600 Air Expressway, CA 92301 and can be downloaded at [www.adelantoca.gov](http://www.adelantoca.gov)

Permits should be reviewed in no more than ten working days once the submittal is accepted and plan check fees have been paid.

### 4. Fees

Fees shall be determined as adopted by the City Council in the latest fee recovery schedule available at [www.adelantoca.gov](http://www.adelantoca.gov)

### 5. Inspections

Once all permits to construct the solar installation have been issued and the system has been installed, it must be inspected before final approval is granted for the solar system. On-site inspections can be scheduled by contacting City of Adelanto Building Division by telephone at (760) 246 2300 ex 11181.

Inspection requests received within business hours are typically scheduled for the next business day. If next business day is not available, inspection should happen within a five-day window.

Permit holders must be prepared to show conformance with all technical requirements in the field at the time of inspection. The inspector will verify that the installation is in conformance with applicable code requirements and with the approved plans. The contractor must provide access to all portions of the installation and provide a ladder for safe access to the roof.

The inspection checklist provides an overview of common points of inspection that the applicant should be prepared to show compliance. If not available, common checks include the following.

- Number of PV modules and model number match plans and specification sheets number match plans and specification sheets.
- Array conductors and components are installed in a neat and workman-like manner.
- PV array is properly grounded.
- Electrical boxes are accessible and connections are suitable for environment.
- Array is fastened and sealed according to attachment detail.
- Conductor types, ratings and sizes match plans.
- Appropriate signs are properly constructed, installed and displayed, including the following.
  - Sign identifying PV power source system attributes at DC disconnect
  - Sign identifying AC point of connection
  - Sign identifying switch for alternative power system
- Equipment ratings are consistent with application and installed signs on the installation, including the following.
  - Inverter has a rating as high as max voltage on PV power source sign.
  - DC-side overcurrent circuit protection devices (OCPDs) are DC rated at least as high as max voltage on sign.
  - Switches and OCPDs are installed according to the manufacturer's specifications (i.e., many 600VDC switches require passing through the switch poles twice in a specific way).
  - Inverter is rated for the site AC voltage supplied and shown on the AC point of connection sign.
  - OCPD connected to the AC output of the inverter is rated at least 125% of maximum current on sign and is no larger than the maximum OCPD on the inverter listing label.
  - Sum of the main OCPD and the inverter OCPD is rated for not more than 120% of the bus bar rating.

## 6. Departmental Contact Information

For additional information regarding this permit process, please consult our City of Adelanto website at [www.adelantoca.gov](http://www.adelantoca.gov) or call our Building & Safety line at (760) 246 2300. For more information regarding general requirements for small solar systems, visit: [www.opr.ca.gov/docs/solar\\_permitting\\_guidebook\\_winter\\_winter\\_2017\\_update.pdf](http://www.opr.ca.gov/docs/solar_permitting_guidebook_winter_winter_2017_update.pdf)